

## Traceable RFID Tag Performance Measurements

Dr Hui Shao  
JX Instrumentation Co Ltd



聚星定制, 您的仪器

1

## Agenda

- About JXI
- Traceable Tag Measurement Theories
- Traceable Measurement Practices
- Conclusion



聚星定制, 您的仪器



2

## JX Instrumentation

- Modular Instrumentation Company
  - RFID, Radio Monitoring Systems and Modules
- World Class Team
  - Strong R&D Investment since 2004
  - Qualified RFID Testers
  - Standard Work Group Member
  - 200+ RFID Test Systems Sold to 100+ Customers
  - Office in Shanghai, Beijing, XiAn, Guangdong, Chongqing, Chengdu
  - Partners in Japan, Austra, Korea, US...




聚星定制, 您的仪器



3

## 800-900MHz Tag Sensitivities

- Received Isotropic Radiated Power (EPC)
  - $RIP(dBm) = EIRP - PL$
  - $EIRP = P_{Tx} + G_{Tx}$



聚星定制, 您的仪器



4

## 800-900MHz Tag Sensitivities (cont.)

- Magnetic Field Threshold (ISO 18046-3)
  - $E(V/m) = \frac{\sqrt{30 \cdot EIRP(W)}}{R(m)} = \frac{\sqrt{P_{Tx}(W) \cdot G_{Tx}}}{R} \cdot 5.477$
  - Measure  $P_{Tx}$ , Calibrate  $G_{Tx}$
- Field Strength is derived from Radiated Power

聚星定制, 您的仪器



5

## Free Space Path Loss (FSPL)

- $P_{Rx} = P_{Tx} G_{Tx} G_{Rx} \frac{Ae}{4\pi R^2}$
- $Ae = \frac{\lambda^2}{4\pi}$
- $PL = \left(\frac{4\pi R}{\lambda}\right)^2$
- $PL(dB) = 20 \log\left(\frac{4\pi R}{\lambda}\right)$
- $E(V/m) = \frac{\sqrt{30 \cdot EIRP(W)}}{R(m)} = \frac{4\pi}{\lambda} \sqrt{30 \cdot RIP}$

$$RIP(dBm) = EIRP - PL$$


聚星定制, 您的仪器



6

## Read Range (EPC)

- Read Range, derived from sensitivity
  - Assumes reader EIRP=35dBm
  - $Range(m) = R * 10^{\frac{35 - EIRP_{Tx}(dBm)}{20}}$
- Backscatter Range, derived from tag return power
  - Tx power = Threshold power(sensitivity) + 2dB
  - Assume reader sensitivity -70dBm, antenna gain 5dBil
  - $Range_{RL} = (10^{K/10})^{1/4} * R$
  - $K = 110 - EIRP_{Tx0} + P_{Rx0} - G_{Rx}$
  - $EIRP_{Tx0} = EIRP_{Tx} + 2$




聚星定制，您的仪器



7

## Calibration with Reference Antenna

- Tool: Reference Antenna with known Gain
  - Method 1: calibrate Tx antenna gain
  - Method 2:  $RIP = P_{ref} - G_{ref} | P_{Tx} = \text{threshold}$




聚星定制，您的仪器



8

## Calibration of Ref Antenna

- EPC Tag Performance Parameters and Test Methods
  - If you have 3 ref antennas (section 7.4)
  - $G_1 + G_2 = S21[1,2] + PL(dB)$  enough if  $G_1$  is known or  $G_1 = G_2$
  - $G_2 + G_3 = S21[1,2] + PL(dB)$
  - $G_3 + G_1 = S21[1,2] + PL(dB)$
  - Method ref SAE ARP958




聚星定制，您的仪器



9

## JXI Traceable Calibrations

- Working with Metrology Labs
  - China Electronics Standardization Institute
  - National Institute of Metrology
  - MET Labs
- Customers Certified
  - CNAS
  - EPC QTS



中国电子技术标准化研究院  
China Electronics Standardization Institute


中国计量科学研究院  
National Institute of Metrology, China

聚星定制，您的仪器



10

## Global Compare EPCglobal TLRPP Workgroup



聚星定制，您的仪器



11

## Practice: Far-field and Reflection


- Accuracy: Far-field & Reflection-free
- Office Test: Dipole 200,300...800mm
- Practical Far-field:  $3\lambda$ , 1m  $D^2/\lambda$  may not enough




聚星定制，您的仪器




12




13




14




15



16



17



18

## Conclusion

- Tag Tester Calibrates with Reference Antenna
- Standards:
  - Power Meter, Network Analyzer
- JXI Provides Traceable RFID Testers
  - Tag and reader, since 2005



聚星定制，您的仪器

